j) Cayman Brac Faith Hospital WAC Piped Water Overseas Testing 2021

CLIENT_SAMPLE_DESCRIPTION	MATRIX	DATE_SAMP	TSAMP	DATE_ANAL	DATE_PREP	ANALYSIS_METHOD	SDG_NUM	CAS_NUMBER	COMPOUND_NAME	UNITS	ReportedResult	NUMERIC_RESULT	A_RESULT	RL	MDL	DIL_FACTOR	BATCH_ID	PCT_SOLIDS	BASIS	COMPOUND_TYPE
CYB FaithHospita	Water	31-08-21	00-01-00 13:30	09-09-21			524.2	71-43-2	Benzene	mg/L	<0.000082	0.000082	<U H H3	0.0005	0.000082		1 680-684087		0 Total	TARGET
CYB FaithHospita	Water	31-08-21	00-01-00 13:30	09-09-21			524.2	56-23-5	Carbon tetrachloride	mg/L	<0.00011	0.00011	<U H H3 *+	0.0005	0.00011		1 680-684087		0 Total	TARGET
CYB FaithHospita	Water	31-08-21	00-01-00 13:30	09-09-21			524.2	108-90-7	Chlorobenzene	mg/L	<0.00014	0.00014	<U H H3	0.0005	0.00014		1 680-684087		0 Total	TARGET
CYB FaithHospita	Water	31-08-21	00-01-00 13:30	09-09-21			524.2	95-50-1	1,2-Dichlorobenzene	mg/L	<0.00016	0.00016	<U H H3	0.0005	0.00016		1 680-684087		0 Total	TARGET
CYB FaithHospita	Water	31-08-21	00-01-00 13:30	09-09-21			524.2	106-46-7	1,4-Dichlorobenzene	mg/L	<0.00013	0.00013	<U H H3	0.0005	0.00013		1 680-684087		0 Total	TARGET
CYB FaithHospita	Water	31-08-21	00-01-00 13:30	09-09-21			524.2	107-06-2	1,2-Dichloroethane	mg/L	<0.000086	0.000086	<U H H3	0.0005	0.000086		1 680-684087		0 Total	TARGET
CYB FaithHospita	Water	31-08-21	00-01-00 13:30	09-09-21			524.2	75-35-4	1,1-Dichloroethene	mg/L	<0.00015	0.00015	<U H H3	0.0005	0.00015		1 680-684087		0 Total	TARGET
CYB FaithHospita	Water	31-08-21	00-01-00 13:30	09-09-21			524.2	156-59-2	cis-1,2-Dichloroethene	mg/L	<0.00009	0.00009	<U H H3 *1	0.0005	0.00009		1 680-684087		0 Total	TARGET
CYB FaithHospita	Water	31-08-21	00-01-00 13:30	09-09-21			524.2	156-60-5	trans-1,2-Dichloroethene	mg/L	<0.00009	0.00009	<U H H3	0.0005	0.00009		1 680-684087		0 Total	TARGET
CYB FaithHospita	Water	31-08-21	00-01-00 13:30	09-09-21			524.2	78-87-5	1,2-Dichloropropane	mg/L	<0.000096	0.000096	<U H H3 *1	0.0005	0.000096		1 680-684087		0 Total	TARGET
CYB FaithHospita	Water	31-08-21	00-01-00 13:30	09-09-21			524.2	100-41-4	Ethylbenzene	mg/L	<0.000099	0.000099	<U H H3	0.0005	0.000099		1 680-684087		0 Total	TARGET
CYB FaithHospita	Water	31-08-21	00-01-00 13:30	09-09-21			524.2	75-09-2	Methylene Chloride	mg/L	0.0003 J	0.0003	J H H3 B	0.0005	0.0002		1 680-684087		0 Total	TARGET
CYB FaithHospita	Water	31-08-21	00-01-00 13:30	09-09-21			524.2	100-42-5	Styrene	mg/L	<0.000089	0.000089	<U H H3	0.0005	0.000089		1 680-684087		0 Total	TARGET
CYB FaithHospita	Water	31-08-21	00-01-00 13:30	09-09-21			524.2	127-18-4	Tetrachloroethene	mg/L	<0.00018	0.00018	<U H H3	0.0005	0.00018		1 680-684087		0 Total	TARGET
CYB FaithHospita	Water	31-08-21	00-01-00 13:30	09-09-21			524.2	108-88-3	Toluene	mg/L	<0.000086	0.000086	<U H H3	0.0005	0.000086		1 680-684087		0 Total	TARGET
CYB FaithHospita	Water	31-08-21	00-01-00 13:30	09-09-21			524.2	120-82-1	1,2,4-Trichlorobenzene	mg/L	<0.00012	0.00012	<U H H3	0.0005	0.00012		1 680-684087		0 Total	TARGET
CYB FaithHospita	Water	31-08-21	00-01-00 13:30	09-09-21			524.2	71-55-6	1,1,1-Trichloroethane	mg/L	<0.00015	0.00015	<U H H3	0.0005	0.00015		1 680-684087		0 Total	TARGET
CYB FaithHospita	Water	31-08-21	00-01-00 13:30	09-09-21			524.2	79-00-5	1,1,2-Trichloroethane	mg/L	<0.00016	0.00016	<U H H3	0.0005	0.00016		1 680-684087		0 Total	TARGET
CYB FaithHospita	Water	31-08-21	00-01-00 13:30	09-09-21			524.2	75-01-4	Vinyl chloride	mg/L	<0.00016	0.00016	<U H H3	0.0005	0.00016		1 680-684087		0 Total	TARGET
CYB FaithHospita	Water	31-08-21	00-01-00 13:30	09-09-21			524.2	67-66-3	Chloroform	mg/L	<0.0002	0.0002	<U H H3	0.0005	0.0002		1 680-684087		0 Total	TARGET
CYB FaithHospita	Water	31-08-21	00-01-00 13:30	09-09-21			524.2	75-27-4	Dichlorobromomethane	mg/L	0.00015 J	0.00015	J H H3	0.0005	0.000079		1 680-684087		0 Total	TARGET
CYB FaithHospita	Water	31-08-21	00-01-00 13:30	09-09-21			524.2	75-25-2	Bromoform	mg/L	0.0031	0.0031	H H3	0.0005	0.00017		1 680-684087		0 Total	TARGET
CYB FaithHospita	Water	31-08-21	00-01-00 13:30	09-09-21			524.2	124-48-1	Chlorodibromomethane	mg/L	0.00074	0.00074	H H3	0.0005	0.00013		1 680-684087		0 Total	TARGET
CYB FaithHospita	Water	31-08-21	00-01-00 13:30	09-09-21			524.2	1634-04-4	Methyl tert-butyl ether	mg/L	<0.000093	0.000093	<U H H3	0.0005	0.000093		1 680-684087		0 Total	TARGET
CYB FaithHospita	Water	31-08-21	00-01-00 13:30	09-09-21			524.2	91-20-3	Naphthalene	mg/L	<0.00043	0.00043	<U H H3	0.001	0.00043		1 680-684087		0 Total	TARGET
CYB FaithHospita	Water	31-08-21	00-01-00 13:30	09-09-21			524.2	79-34-5	1,1,2,2-Tetrachloroethane	mg/L	<0.00013	0.00013	<U H H3	0.0005	0.00013		1 680-684087		0 Total	TARGET
CYB FaithHospita	Water	31-08-21	00-01-00 13:30	09-09-21			524.2	79-01-6	Trichloroethene	mg/L	<0.00013	0.00013	<U H H3	0.0005	0.00013		1 680-684087		0 Total	TARGET
CYB FaithHospita	Water	31-08-21	00-01-00 13:30	09-09-21			524.2	1330-20-7	Xylenes, Total	mg/L	<0.000086	0.000086	<U H H3	0.0005	0.000086		1 680-684087		0 Total	TARGET
CYB FaithHospita	Water	31-08-21	00-01-00 13:30	09-09-21	44386			7440-50-8	Copper	mg/L	<0.0018	0.0018	<U	0.02	0.0018		1 680-684317		0 Total	TARGET
CYB FaithHospita	Water	31-08-21	00-01-00 13:30	09-09-21	44386			7439-89-6	Iron	mg/L	<0.017	0.017	<U	0.05	0.017		1 680-684317		0 Total	TARGET
CYB FaithHospita	Water	31-08-21	00-01-00 13:30	09-09-21	44386			7439-96-5	Manganese	mg/L	<0.001	0.001	<U	0.01	0.001		1 680-684317		0 Total	TARGET
CYB FaithHospita	Water	31-08-21	00-01-00 13:30	09-09-21	44386			7440-66-6	Zinc	mg/L	0.46	0.46		0.02	0.007		1 680-684317		0 Total	TARGET
CYB FaithHospita	Water	31-08-21	00-01-00 13:30	14-09-21	44453	525.2		15972-60-8	Alachlor	ug/L	<0.049	0.049	<U	0.097	0.049		1 810-3195		0 Total	TARGET
CYB FaithHospita	Water	31-08-21	00-01-00 13:30	14-09-21	44453	525.2		309-00-2	Aldrin	ug/L	<0.019	0.019	<U	0.097	0.019		1 810-3195		0 Total	TARGET
CYB FaithHospita	Water	31-08-21	00-01-00 13:30	14-09-21	44453	525.2		1912-24-9	Atrazine	ug/L	<0.029	0.029	<U	0.097	0.029		1 810-3195		0 Total	TARGET
CYB FaithHospita	Water	31-08-21	00-01-00 13:30	14-09-21	44453	525.2		50-32-8	Benzo[a]pyrene	ug/L	<0.0097	0.0097	<U	0.019	0.0097		1 810-3195		0 Total	TARGET
CYB FaithHospita	Water	31-08-21	00-01-00 13:30	14-09-21	44453	525.2		23184-66-9	Butachlor	ug/L	<0.049	0.049	<U	0.097	0.049		1 810-3195		0 Total	TARGET
CYB FaithHospita	Water	31-08-21	00-01-00 13:30	14-09-21	44453	525.2		60-57-1	Dieldrin	ug/L	<0.019	0.019	<U	0.097	0.019		1 810-3195		0 Total	TARGET
CYB FaithHospita	Water	31-08-21	00-01-00 13:30	14-09-21	44453	525.2		103-23-1	Di(2-ethylhexyl)adipate	ug/L	<0.58	0.58	<U	0.58	0.58		1 810-3195		0 Total	TARGET
CYB FaithHospita	Water	31-08-21	00-01-00 13:30	14-09-21	44453	525.2		117-81-7	Di (2-ethylhexyl)phthalate	ug/L	<0.58	0.58	<U	0.58	0.58		1 810-3195		0 Total	TARGET
CYB FaithHospita	Water	31-08-21	00-01-00 13:30	14-09-21	44453	525.2		72-20-8	Endrin	ug/L	<0.0097	0.0097	<U *+	0.0097	0.0097		1 810-3195		0 Total	TARGET
CYB FaithHospita	Water	31-08-21	00-01-00 13:30	14-09-21	44453	525.2		58-89-9	gamma-BHC (Lindane)	ug/L	<0.0097	0.0097	<U	0.019	0.0097		1 810-3195		0 Total	TARGET
CYB FaithHospita	Water	31-08-21	00-01-00 13:30	14-09-21	44453	525.2		76-44-8	Heptachlor	ug/L	<0.0097	0.0097	<U	0.039	0.0097		1 810-3195		0 Total	TARGET
CYB FaithHospita	Water	31-08-21	00-01-00 13:30	14-09-21	44453	525.2		1024-57-3	Heptachlor epoxide	ug/L	<0.019	0.019	<U	0.019	0.019		1 810-3195		0 Total	TARGET
CYB FaithHospita	Water	31-08-21	00-01-00 13:30	14-09-21	44453	525.2		118-74-1	Hexachlorobenzene	ug/L	<0.0097	0.0097	<U	0.097	0.0097		1 810-3195		0 Total	TARGET
CYB FaithHospita	Water	31-08-21	00-01-00 13:30	14-09-21	44453	525.2		77-47-4	Hexachlorocyclopentadiene	ug/L	<0.0097	0.0097	<U	0.097	0.0097		1 810-3195		0 Total	TARGET
CYB FaithHospita	Water	31-08-21	00-01-00 13:30	14-09-21	44453	525.2		72-43-5	Methoxychlor	ug/L	<0.049	0.049	<U	0.097	0.049		1 810-3195		0 Total	TARGET
CYB FaithHospita	Water	31-08-21	00-01-00 13:30	14-09-21	44453	525.2		51218-45-2	Metolachlor	ug/L	<0.049	0.049	<U	0.097	0.049		1 810-3195		0 Total	TARGET
CYB FaithHospita	Water	31-08-21	00-01-00 13:30	14-09-21	44453	525.2		21087-64-9	Metribuzin	ug/L	<0.058	0.058	<U	0.097	0.058		1 810-3195		0 Total	TARGET
CYB FaithHospita	Water	31-08-21	00-01-00 13:30	14-09-21	44453	525.2		1918-16-7	Propachlor	ug/L	<0.039	0.039	<U	0.097	0.039		1 810-3195		0 Total	TARGET
CYB FaithHospita	Water	31-08-21	00-01-00 13:30	14-09-21	44453	525.2		122-34-9	Simazine	ug/L	<0.029	0.029	<U	0.068	0.029		1 810-3195		0 Total	TARGET
CYB FaithHospita	Water	31-08-21	00-01-00 13:30	09-09-21	44386			7440-23-5	Sodium	ug/L	53000	53000		1000	480		1 680-684317		0 Total	TARGET
CYB FaithHospita	Water	31-08-21	00-01-00 13:30	09-09-21	44386			7440-38-2	Arsenic	ug/L	<0.37	0.37	<U	1	0.37		1 680-684053		0 Total	TARGET
CYB FaithHospita	Water	31-08-21	00-01-00 13:30	09-09-21	44386			7440-39-3	Barium	ug/L	<0.14	0.14	<U	2	0.14		1 680-684053		0 Total	TARGET
CYB FaithHospita	Water	31-08-21	00-01-00 13:30	09-09-21	44386			7440-43-9	Cadmium	ug/L	<0.043	0.043	<U	0.5	0.043		1 680-684053		0 Total	TARGET
CYB FaithHospita	Water	31-08-21	00-01-00 13:30	09-09-21	44386			7440-47-3	Chromium	ug/L	<1	1	<U	2	1		1 680-684053		0 Total	TARGET
CYB FaithHospita	Water	31-08-21	00-01-00 13:30	09-09-21	44386			7440-02-0	Nickel	ug/L	0.49 J	0.49	J	5	0.4		1 680-684053		0 Total	TARGET
CYB FaithHospita	Water	31-08-21	00-01-00 13:30	09-09-21	44386			7439-92-1	Lead	ug/L	0.13 J	0.13	J	0.3	0.06		1 680-684053		0 Total	TARGET
CYB FaithHospita	Water	31-08-21	00-01-00 13:30	09-09-21	44386			7440-36-0	Antimony	ug/L	<0.4	0.4	<U	1	0.4		1 680-684053		0 Total	TARGET
CYB FaithHospita	Water	31-08-21	00-01-00 13:30	09-09-21	44386			7782-49-2	Selenium	ug/L	<0.58	0.58	<U	2	0.58		1 680-684053		0 Total	TARGET
CYB FaithHospita	Water	31-08-21	00-01-00 13:30	09-09-21	44386			7440-42-8	Boron	ug/L	870	870		20	4.8		1 680-684053		0 Total	TARGET
CYB FaithHospita	Water	31-08-21	00-01-00 13:30	09-09-21	44386			7439-97-6	Mercury	ug/L	<0.058	0.058	<U	0.2	0.058		1 680-684053		0 Total	TARGET