

c) ST Mental Health Facility WAC Piped Water Overseas Testing 2021

CLIENT_SAMPLE_DESCRIPTION	MATRIX	DATE_ENTERED	YEAR	DATE_ANAL	DATE_PRINT	ANALYSIS_METHOD	SQG_NUM	CAS_NUMBER	COMPOUND_NAME	UNITS	ReportedResult	LOWER_ACTION	UPPER_ACTION	MG	MG/L	DRIFT_FACTOR	BATCH_ID	PCY_SQUID	STATUS	COMPOUND_TYPE
ST Mental Health Facility	Water	08-03-21	00-01-00 10-11	08-05-21		524.2		71-43-2	Benzene	mg/L	<0.000082	0.000082	<U H H3	0.0005	0.000082	0.0005	1 680-679574	0	Total	TARGET
ST Mental Health Facility	Water	08-03-21	00-01-00 10-11	08-05-21		524.2		56-23-5	Carbon tetrachloride	mg/L	<0.000114	0.000114	<U H H3	0.0005	0.000114	0.0005	1 680-679574	0	Total	TARGET
ST Mental Health Facility	Water	08-03-21	00-01-00 10-11	08-05-21		524.2		108-90-7	Chlorobenzene	mg/L	<0.00014	0.00014	<U H H3	0.0005	0.00014	0.0005	1 680-679574	0	Total	TARGET
ST Mental Health Facility	Water	08-03-21	00-01-00 10-11	08-05-21		524.2		95-50-1	1,2-Dichlorobenzene	mg/L	<0.00016	0.00016	<U H H3	0.0005	0.00016	0.0005	1 680-679574	0	Total	TARGET
ST Mental Health Facility	Water	08-03-21	00-01-00 10-11	08-05-21		524.2		106-46-7	1,4-Dichlorobenzene	mg/L	<0.00013	0.00013	<U H H3	0.0005	0.00013	0.0005	1 680-679574	0	Total	TARGET
ST Mental Health Facility	Water	08-03-21	00-01-00 10-11	08-05-21		524.2		107-06-2	1,2-Dichloroethane	mg/L	<0.000086	0.000086	<U H H3	0.0005	0.000086	0.0005	1 680-679574	0	Total	TARGET
ST Mental Health Facility	Water	08-03-21	00-01-00 10-11	08-05-21		524.2		75-35-4	1,1-Dichloroethane	mg/L	<0.00015	0.00015	<U H H3	0.0005	0.00015	0.0005	1 680-679574	0	Total	TARGET
ST Mental Health Facility	Water	08-03-21	00-01-00 10-11	08-05-21		524.2		156-59-2	cis-1,2-Dichloroethene	mg/L	<0.00009	0.00009	<U H H3	0.0005	0.00009	0.0005	1 680-679574	0	Total	TARGET
ST Mental Health Facility	Water	08-03-21	00-01-00 10-11	08-05-21		524.2		156-60-5	trans-1,2-Dichloroethene	mg/L	<0.00009	0.00009	<U H H3	0.0005	0.00009	0.0005	1 680-679574	0	Total	TARGET
ST Mental Health Facility	Water	08-03-21	00-01-00 10-11	08-05-21		524.2		78-87-5	1,2-Dichloropropane	mg/L	<0.000099	0.000099	<U H H3	0.0005	0.000099	0.0005	1 680-679574	0	Total	TARGET
ST Mental Health Facility	Water	08-03-21	00-01-00 10-11	08-05-21		524.2		100-41-4	Ethylbenzene	mg/L	<0.000099	0.000099	<U H H3	0.0005	0.000099	0.0005	1 680-679574	0	Total	TARGET
ST Mental Health Facility	Water	08-03-21	00-01-00 10-11	08-05-21		524.2		75-09-2	Methylene Chloride	mg/L	<0.0002	0.0002	<U H H3	0.0005	0.0002	0.0005	1 680-679574	0	Total	TARGET
ST Mental Health Facility	Water	08-03-21	00-01-00 10-11	08-05-21		524.2		100-42-5	Styrene	mg/L	<0.000089	0.000089	<U H H3	0.0005	0.000089	0.0005	1 680-679574	0	Total	TARGET
ST Mental Health Facility	Water	08-03-21	00-01-00 10-11	08-05-21		524.2		127-18-4	Tetrachloroethene	mg/L	<0.00018	0.00018	<U H H3	0.0005	0.00018	0.0005	1 680-679574	0	Total	TARGET
ST Mental Health Facility	Water	08-03-21	00-01-00 10-11	08-05-21		524.2		108-88-3	Toluene	mg/L	<0.000086	0.000086	<U H H3	0.0005	0.000086	0.0005	1 680-679574	0	Total	TARGET
ST Mental Health Facility	Water	08-03-21	00-01-00 10-11	08-05-21		524.2		120-82-1	1,1,1-Trichlorobenzene	mg/L	<0.00012	0.00012	<U H H3	0.0005	0.00012	0.0005	1 680-679574	0	Total	TARGET
ST Mental Health Facility	Water	08-03-21	00-01-00 10-11	08-05-21		524.2		71-55-6	1,1,1-Trichloroethane	mg/L	<0.00015	0.00015	<U H H3	0.0005	0.00015	0.0005	1 680-679574	0	Total	TARGET
ST Mental Health Facility	Water	08-03-21	00-01-00 10-11	08-05-21		524.2		79-00-5	1,1,2-Trichloroethane	mg/L	<0.00016	0.00016	<U H H3	0.0005	0.00016	0.0005	1 680-679574	0	Total	TARGET
ST Mental Health Facility	Water	08-03-21	00-01-00 10-11	08-05-21		524.2		75-01-4	Vinyl chloride	mg/L	<0.00016	0.00016	<U H H3	0.0005	0.00016	0.0005	1 680-679574	0	Total	TARGET
ST Mental Health Facility	Water	08-03-21	00-01-00 10-11	08-05-21		524.2		67-66-3	Chloroform	mg/L	<0.0002	0.0002	<U H H3	0.0005	0.0002	0.0005	1 680-679574	0	Total	TARGET
ST Mental Health Facility	Water	08-03-21	00-01-00 10-11	08-05-21		524.2		75-27-4	Dichlorobromomethane	mg/L	<0.000079	0.000079	<U H H3	0.0005	0.000079	0.0005	1 680-679574	0	Total	TARGET
ST Mental Health Facility	Water	08-03-21	00-01-00 10-11	08-05-21		524.2		75-25-2	Bromoform	mg/L	0.0072	0.0072	H H3	0.0005	0.00017	0.0005	1 680-679574	0	Total	TARGET
ST Mental Health Facility	Water	08-03-21	00-01-00 10-11	08-05-21		524.2		124-48-1	Chlorodibromomethane	mg/L	0.00056	0.00056	H H3	0.0005	0.00013	0.0005	1 680-679574	0	Total	TARGET
ST Mental Health Facility	Water	08-03-21	00-01-00 10-11	08-05-21		524.2		1634-04-4	Methyl tert-butyl ether	mg/L	<0.00013	0.00013	<U H H3	0.0005	0.00013	0.0005	1 680-679574	0	Total	TARGET
ST Mental Health Facility	Water	08-03-21	00-01-00 10-11	08-05-21		524.2		91-20-3	Naphthalene	mg/L	<0.00043	0.00043	<U H H3	0.0005	0.00043	0.0005	1 680-679574	0	Total	TARGET
ST Mental Health Facility	Water	08-03-21	00-01-00 10-11	08-05-21		524.2		79-34-5	1,1,2,2-Tetrachloroethane	mg/L	<0.00013	0.00013	<U H H3	0.0005	0.00013	0.0005	1 680-679574	0	Total	TARGET
ST Mental Health Facility	Water	08-03-21	00-01-00 10-11	08-05-21		524.2		79-01-6	Trichloroethene	mg/L	<0.000086	0.000086	<U H H3	0.0005	0.000086	0.0005	1 680-680866	0	Total	TARGET
ST Mental Health Facility	Water	08-03-21	00-01-00 10-11	08-05-21		524.2		1330-20-7	Xylenes, Total	mg/L	0.00231	0.00231	<U H H3	0.0005	0.00018	0.02	1 680-680866	0	Total	TARGET
ST Mental Health Facility	Water	08-03-21	00-01-00 10-11	08-05-21		524.2		7440-50-8	Copper	mg/L	0.017	0.017	<U	0.05	0.017	0.017	1 680-680866	0	Total	TARGET
ST Mental Health Facility	Water	08-03-21	00-01-00 10-11	08/13/2021	08/13/2021	2007 Rev 4.4		7439-89-6	Iron	mg/L	<0.001	0.001	<U	0.01	0.001	0.001	1 680-680866	0	Total	TARGET
ST Mental Health Facility	Water	08-03-21	00-01-00 10-11	08/13/2021	08/13/2021	2007 Rev 4.4		7440-50-8	Zinc	mg/L	0.48	0.48	<U	0.02	0.007	0.007	1 680-680866	0	Total	TARGET
ST Mental Health Facility	Water	08-03-21	00-01-00 10-11	08/13/2021	08/13/2021	2007 Rev 4.4		7439-89-6	Manganese	mg/L	<0.001	0.001	<U	0.01	0.001	0.001	1 680-680866	0	Total	TARGET
ST Mental Health Facility	Water	08-03-21	00-01-00 10-11	08/13/2021	08/13/2021	2007 Rev 4.4		7440-38-2	Sodium	ug/L	51000	51000	<U	1000	480	480	1 680-680866	0	Total	TARGET
ST Mental Health Facility	Water	08-03-21	00-01-00 10-11	08/13/2021	08/13/2021	2008 1994 RS 4		7440-38-2	Arsenic	ug/L	<0.37	0.37	<U	1	0.37	0.37	1 680-680917	0	Total	TARGET
ST Mental Health Facility	Water	08-03-21	00-01-00 10-11	08/13/2021	08/13/2021	2008 1994 RS 4		7440-39-3	Barium	ug/L	0.171	0.171	<U	2	0.14	0.14	1 680-680917	0	Total	TARGET
ST Mental Health Facility	Water	08-03-21	00-01-00 10-11	08/13/2021	08/13/2021	2008 1994 RS 4		7440-43-9	Cadmium	ug/L	<0.043	0.043	<U	0.5	0.043	0.043	1 680-680917	0	Total	TARGET
ST Mental Health Facility	Water	08-03-21	00-01-00 10-11	08/13/2021	08/13/2021	2008 1994 RS 4		7440-47-3	Chromium	ug/L	<1	1	<U	2	1	1	1 680-680917	0	Total	TARGET
ST Mental Health Facility	Water	08-03-21	00-01-00 10-11	08/13/2021	08/13/2021	2008 1994 RS 4		7440-02-0	Nickel	ug/L	<0.4	0.4	<U	5	0.4	0.4	1 680-680917	0	Total	TARGET
ST Mental Health Facility	Water	08-03-21	00-01-00 10-11	08/13/2021	08/13/2021	2008 1994 RS 4		7439-97-1	Lead	ug/L	<0.4	0.4	<U	0.3	0.06	0.06	1 680-680917	0	Total	TARGET
ST Mental Health Facility	Water	08-03-21	00-01-00 10-11	08/13/2021	08/13/2021	2008 1994 RS 4		7440-36-0	Antimony	ug/L	<0.4	0.4	<U	1	0.4	0.4	1 680-680917	0	Total	TARGET
ST Mental Health Facility	Water	08-03-21	00-01-00 10-11	08/13/2021	08/13/2021	2008 1994 RS 4		7782-49-2	Selenium	ug/L	<0.58	0.58	<U	2	0.58	0.58	1 680-680917	0	Total	TARGET
ST Mental Health Facility	Water	08-03-21	00-01-00 10-11	08/13/2021	08/13/2021	2008 1994 RS 4		7440-42-8	Boron	ug/L	910	910	<U	20	4.8	4.8	1 680-680917	0	Total	TARGET
ST Mental Health Facility	Water	08-03-21	00-01-00 10-11	08/13/2021	08/13/2021	2008 1994 RS 4		7439-97-6	Mercury	ug/L	<0.058	0.058	<U	0.2	0.058	0.058	1 680-680917	0	Total	TARGET